



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
430, G.T. Road, Howrah(N), Pin :- 711101

Memo No.:FSR/0125186231300515

Date : 06-10-2024

From :
Divisional Fire Officer
Howrah Division,
West Bengal Fire & Emergency Services

To :
THE SCHOLAR SCHOOL
LR DAG NO- 3089, KH NO- 1233, JL NO- 47, MOUZA- RABIBHAG, CHANDRABHAG G.P., BAGNAN

Sub : Fire Safety Certificate an existing construction of G + 1 storied School building under group of Educational Occupancy in the name & style of 'THE SCHOLAR SCHOOL' at the premises no MOUZA- RABIBHAG, JL NO- 47, LR DAG NO- 3089, KH NO- 1233 (old) & 89. 945, 2998, 2083, 292, 1010, 1239, 1301, 26(new) 4047, UNDER CHANDRABHAG G.P., BAGNAN II BLOCK P.S- BAGNAN, HOWRAH.

This is in reference to your AIN 211892406300002448 dated 29-Sep-2024 regarding Fire Safety Certificate an existing construction of G + 1 storied School building under group of Educational Occupancy in the name & style of 'THE SCHOLAR SCHOOL' at the premises no MOUZA- RABIBHAG, JL NO- 47, LR DAG NO- 3089, KH NO- 1233 (old) & 89. 945, 2998, 2083, 292, 1010, 1239, 1301, 26(new) 4047, UNDER CHANDRABHAG G.P., BAGNAN II BLOCK P.S- BAGNAN, HOWRAH..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

This is in reference to your application AIN – 211892406300002448 Dated -15-Jul-2024 Regarding the Fire Safety Certificate for of an existing construction of G + 1 storied School building under group of 'Educational Occupancy' in the name & style of 'THE SCHOLAR SCHOOL' at the premises no MOUZA- RABIBHAG, JL NO- 47, LR DAG NO- 3089, KH NO- 1233 (old) & 89. 945, 2998, 2083, 292, 1010, 1239, 1301, 26(new) 4047, UNDER CHANDRABHAG G.P., BAGNAN II BLOCK P.S- BAGNAN,



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300002448

HOWRAH.

The performance of the Fire Fighting System as incorporated in the aforesaid building was tested random and found satisfactory working condition during inspection .In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety measure, the following safety measures need to be incorporated.

- 01) Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
 - 02) All the Entrance and Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
 - 03) The interior finish decoration of aforesaid premises shall be made with low flame spread material confirming to the I.S. Specification.
 - 04) To eliminate risk of Fire Hazards, Good House Keeping both for insides and outsides of the aforesaid premises shall be strictly maintained.
 - 05) Existing Electrical wiring of the whole aforesaid premises shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
 - 06) A Fire Control Room including a closed circuit T.V. system will have to be maintained which observe all floor of the aforesaid premises.
 - 07) The notice of Fire Fighting and Evacuation from the aforesaid premises shall be prepared and displayed at all vulnerable of the Aforesaid premises.
 - 08) The Employees and Security Staff shall be conversant with installed Fire Fighting equipment's of the aforesaid premises and to operate in the event of Fire and Testing.
 - 09) Mock Fire Practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the aforesaid premises.
 - 10) Transformer and Switch gear shall be protected with automatic CO2 or D.C.P. Fire extinction confirming I.S. Specification.
 - 11) A Crew of Trained Fireman under an Experienced Officer shall be maintained round the clock for safety of the aforesaid premises.
 - 12) The system of Auto shut down of A.H.U. shall be incorporated with the Auto Detection & Alarm system.
 - 13) First- Aid Fire Fighting system shall be provided as per I.S. Specification.
 - 14) Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
 - 15) If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
 - 16) Periodical flashing of water in the Hydrants and Sprinkler pipe lines shall be made to maintain the efficiency working performance of above mention system.
 - 17) All Fire pumps, Alarm and detection system which are incorporated in the building shall be kept in auto mode round the clock.
 - 18) Fire safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
 - 19) Adequate numbers of Fire Escape mask shall be provided of the building.
 - 20) The Head of the organization/Society as the case may be, shall submit a declaration to the Director General, West Bengal Fire & Emergency Services on every 1st April, 1st July, 1st October & 1st January maintaining financial calendar that "The Fire Prevention and Fire Safety Measures in the building or premises have been tasted and are in good working condition. That, no material changes has been done in the building that has affected the Means of Escape and Means of Access as the case may be. That, all the members of the organization are well conversant with the Evacuation Drill and mentally & physically fit to combat the Fire Emergencies. That, any deviation in the above and failure in maintenance of the Fire Prevention and Fire Safety measures shall at the risk and liability of the Head of the organization / Society.
- This FIRE SAFETY CERTIFICATE is valid for 03(Three) years from the date of issuance of This Certificate. After three year a Renewal Fire Safety Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services for performance of all the Life & Fire Safety arrangements & Installations of the Building.



Valid Upto : 05-Oct-2027

Memo No.:FSR/0125186231300515



Signature valid

Digitally Signed.
Name: Ranjan Kumar Ghosh
Date: 06-Oct-2022 23:43:31
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300002448