

ANANDANIKETAN SUB-DISTRICT LABORATORY

Under PHED

Vill & P.O.:- Barunda, P.S.:- Bagnan, Dist:- Howrah

Sl.No.	Location	Testing Date	Turbidity	pH	Total Hardness	Iron	Manganese	TDS	Arsenic	TC	FC	Remarks	
			Permissible Limit										
			(5 NTU)	(6.5 to 8.5)	(600 mg/l)	(1 mg/l)	(0.3 mg/l)	(2000 mg/l)	(0.01 mg/l)	0			
1	THE SCHOLAR SCHOOL, RABIBHAG, BAGNAN, HOWRAH(RO)	27/08/26	0.29	7.26	164	0.05	0	34.96	0	0	0		
2	THE SCHOLAR SCHOOL, RABIBHAG, BAGNAN, HOWRAH(Pump)	27/08/26	0.46	8.36	192	0.18	0	526.3	0	0	0		

Sample collected by:- Mrinmoy Mishra

Sample was not collected by the department. Hence source not confirmed.

Signature of Chemist

Chemist
Ananda Niketan
Water Testing Laboratory



Signature of Bacteriologist

Bacteriologist
Ananda Niketan
Water Testing Laboratory